Aalborg Universitet



Stability Enhancement of Battery-Testing DC Microgrid

An ADRC Based Virtual Inertia Control Approach

Long, Bo; Zeng, Wei; Rodriguez, Jose; Garcia; Cristian; Guerrero, Josep M.; Chong, Kil to

Published in: IEEE Transactions on Smart Grid

DOI (link to publication from Publisher): 10.1109/TSG.2022.3184985

Publication date: 2022

Document Version Accepted author manuscript, peer reviewed version

Link to publication from Aalborg University

Citation for published version (APA): Long, B., Zeng, W., Rodriguez, J., Garcia, Cristian, Guerrero, J. M., & Chong, K. T. (2022). Stability Enhancement of Battery-Testing DC Microgrid: An ADRC Based Virtual Inertia Control Approach. *IEEE Transactions on Smart Grid*, *13*(6), 4256-4268. https://doi.org/10.1109/TSG.2022.3184985

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain You may freely distribute the URL identifying the publication in the public portal -

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

Stability Enhancement of Battery-Testing DC Microgrid: An ADRC Based Virtual Inertia Control Approach

Bo Long, Senior Member, IEEE, Wei Zeng, José Rodríguez, Life Fellow, IEEE, Garcia, Cristian, Member, IEEE, Josep M. Guerrero Fellow, IEEE, Kil to Chong, Member, IEEE

Abstract—Power batteries play a vital role in electric vehicle (EV) industry. To evaluate their charging and discharging performance and achieve energy recovery, a power accumulator battery testing system (PABTS) based DC-microgrid (DC-MG) is proposed. However, during battery testing, frequent charging and discharging current test may endanger the stability of the PABTS DC-MG. Although, the traditional virtual inertia control (VIC) approach can stabilize the DC-bus voltage, its antiinterference ability is still limited. To solve this problem, an active disturbance rejection control (ADRC) based VIC control scheme is proposed, wherein the VIC approach provides virtual inertia for the system, and the ADRC is derived and modeled using the first-order virtual inertia equation. The external and uncertain internal disturbances in the system are considered for the total disturbance estimation. This disturbance is suppressed by feedback compensation, thereby greatly improving the system robustness. Finally, the effectiveness of the proposed ADRC-VIC method is further verified by experimental results on the laboratory hardware prototype under different scenarios.

Index Terms—Active disturbance rejection control (ADRC), battery testing system (BTS), DC-microgrid (DC-MG), power

Manuscript received January 8, 2022; revised April 23, 2022; accepted June 18 03, 2022. This paper is sponsored by the Fundamental Research Funds for the Central Universities of China (NO. ZYGX2019J033), Key R & D plan of science and technology department of Sichuan province (20ZDYF2816), State Key Laboratory of Control and Simulation of Power System Generation Equipment, China (SKLD20M11), Tsinghua University, China, Guangdong Basic and Applied Basic Research Foundation (2021A1515010666), the support of ANID through projects FB0008 and 1210208, and by the VELUX FOUNDATIONS under the VILLUM Investigator Grant Center for Research on Microgrids (CROM) (No.25920): (Corresponding Author: Kil To Chong.)

Bo Long and Wei Zeng are with the School of Mechanical and Electrical Engineering, Institute for Electric Vehicle Driving System and Safety Technology, University of Electronic Science and Technology of China (UESTC) 611731, China, and with the Yangtze Delta Region Institute (Huzhou), UESTC, Huzhou, 313001, P. R. China, and also with Institute of Electronic and Information Engineering of UESTC in Guangdong, 523808 (e-mail: longboueste1980@126.com; 1935598645@163.com).

J. Rodriguez is with the Faculty of Engineering, Universidad San Sebastian Santiago, Chile. (e-mail: jose.rodriguezp@uss.cl).

Cristian Garcia is with the Department of Electrical Engineering, Faculty of Engineering, Universidad de Talca, Curico 3340000, Chile. (email: cristian.garcia@utalca.cl).

Josep M. Guerrero is with the Department of Energy Technology, Aalborg University, Aalborg DK-9220, Denmark. (e-mail: joz@et.aau.dk).

Kil To Chong is with the Department of Electronics and Information Engineering, Jeonbuk National University, Jeonju 54896, South Korea, (e-mail : kitchong@jbnu.ac.kr).

accumulator battery testing system (PABTS), virtual inertia control (VIC).

NOMENCLATURE

Pout	Output power of BGCC.
P_{in}	Injected dc-bus power.
C_{vir}	Virtual capacitor.
u_{vir}^*	Virtual reference for dc-bus voltage.
C_{dc}	dc-link capacitance.
u_0	Rated dc-bus voltage.
i_0	Output current of BGCC.
i_{dc}^{ref}	Virtual dc-link current reference.
ΔP	Power fluctuation at DC-bus.
D_b	Damping coefficient.
k_d	Droop coefficient.
u_{dc}	dc-link voltage.
i _{a,b,c}	Three-phase grid current in <i>abc</i> -frame.
$v_{a,b,c}$	Three-phase grid voltage in <i>abc</i> -frame.
i _{dq} , u _{dq}	Grid voltage and current under dq-frame.

 Δi Virtual capacitor current.

- *P_{ref}* Active power reference of virtual synchronous machine (VSM).
- P_e Electromagnetic power of VSM.
- D_p Damping coefficient of VSM
- ω Angular frequency of the VSM
- ω_n Rated angular frequency of the utility grid.
- *I* Virtual moment of inertia.

I. INTRODUCTION

WING to the energy crisis and environmental problems caused by the extensive use of conventional fuel vehicles, electric vehicles have become increasingly popular in recent years and have been developed rapidly [1]. Batteries are the key factor affecting the dynamic performance of electric vehicles, which include maximum speed, acceleration, and climbing ability. For now, battery test system is the only way to measure the battery parameters (e.g., voltage, current, internal resistance, state-of-charge (SOC), etc.). Traditional battery test system wastes the energy during the test process through dissipative resistance. To save the test energy, considering that DC-MG is a low-cost and efficient integrated microgrid [2, 3] for renewable energy sources, energy storage systems, and DC loads [4-6], a power accumulator battery testing system (PABTS) based DC-MG is proposed (as shown in Fig.1), where the charging and discharging test control of the



battery is achieved through the bidirectional DC/DC converter, and the DC/DC converter obtains and releases the battery energy through the DC-bus. The bidirectional grid-connected converter (BGCC) is the interface of the DC-bus and ac grid. However, due to the absence of energy storing devices, DC-MG composed by power electronic devices lacks inertia support similar to a mechanical rotor [7, 8]. Additionally, the battery test system itself is an interference for the PABTS DC-MG when continuously charge and discharge tests of the batteries are performed. Thus, for PABTS DC-MG, maintaining the stability of DC-bus voltage under disturbances is challenging.

The existing techniques for stabilization of DC-bus voltage can be categorized by two methods: (1) Droop control and (2) Inertial control.

Droop control has been widely used in microgrids [9-11]. Its primary functions include realization of power sharing between AC-DC microgrids, and between energy storage units [12, 13]. In addition, hierarchical control and droop control in DC-MG are the most basic control methods [14, 15], which standardize the operation of microgrid and improves the performance of microgrid. An observer was applied to the droop control to overcome the limitations of the traditional droop control. This also improved the current sharing accuracy and regulation of the output voltage [11]. It is difficult to balance the voltage regulation accuracy and current sharing accuracy of parallel DC/DC converters in the DC-MG. In [16], a communication free coordinated droop control energy management method was proposed to improve system reliability. In [17], to compensate the voltage deviation in dc-bus due to the droop-control, a distributed secondary control scheme was presented for both current sharing and voltage restoration. A key part of [17] was the integration of a new parameter 'virtual voltage-drop' defined from droop gain and line resistance. However, PABTS DC-MG is different from traditional DC-MG. The charge and discharge test control of battery pack is realized by bidirectional DC/DC converter. The specification of the control parameter varies according to the test requirements. Since each battery pack is tested independently, there is no correlation between each DC/DC converter and no current sharing control. Therefore, droop control may not be suitable for DC/DC converter in PABTS.

Beside droop control, inertia control is also applied for dcbus voltage stabilization of DC-MG, which usually has two methods, one is adding an energy storage system (ESS) [16, 18-20]. Nowadays, the use of energy storage units to compensate for the inertia of the distributed intermittent renewable energy microgrid has been widely discussed. In [18], N. Zhi, K. Ding, et al. proposed a virtual DC motor control of a distributed battery energy storage system to regulate the fluctuation of the DC-bus voltage. To quickly restore the DC-side voltage and achieve power sharing, in [19], hybrid energy storage (e.g. power battery combined with supercapacitor) was also used in to provide inertia support. The static operation of a power electronic converter has no physical inertia, similar to that of a mechanical rotor. The virtual synchronous machine proposed by simulating the rotor equation has been widely used in photovoltaic and wind power generation systems [4, 21]. For example, in [4], a virtual synchronous generator (VSG) is applied as the interface of the energy storage component in wind-storage power generation system, where model predictive controller (MPC) timely changes the reference active power of the VSG according to the change in frequency, which further suppresses the fluctuation of the microgrid's voltage and its frequency. Nevertheless, supercapacitors and batteries only provide inertial support in the transient state of power disturbance and remain idle when the system is stable, resulting in wasted resources and increased costs.

In addition to inertia control with ESS, another technique is virtual inertia control (VIC) without any ESS. Analogy with the VSG rotor equation, a VIC suitable for DC-MG was derived to stabilize the DC-bus voltage on the bidirectional converter [21]. In [22], virtual capacitance was proposed to enhance the system inertia, and droop and damping control were added to analyze the small-signal model of the system, and the feedforward control is used to improve the system stability. On this basis, the stability of the DC-bus voltage was further enhanced by changing the virtual current reference in VIC [23]. Additionally, traditional VIC usually adopts proportional-integral (PI) control (PI-VIC). Owing to its slow time response, its dynamic disturbance cannot be rapidly attenuated, and its linear weighting is not the optimal combination [24, 25]. Generally speaking, PI-VIC is not robust to external interference. Furthermore, the DC-bus voltage fluctuation cannot be minimized. In addition to PI controller for VIC control, there have been some control strategies to obtain high-quality current, such as repetitive control (RC) [26], proportional-resonant (PR) control [27], and sliding-mode control (SMC) [28]. Although RC and PR control schemes can achieve infinite gain at the selected frequencies and achieve zero steady-state error, their robustness is still poor, and the inherent chattering problem in SMC cannot be fully eliminated. In summary, the above controllers are difficult to replace PI controller in PI-VIC to stabilize DC-bus voltage.

Active disturbance rejection control (ADRC), known as a robust control method, can estimate the generalized disturbance, integrate the unknown dynamics, and eliminate the disturbance through feedback compensation, which greatly improves the anti-interference ability of the system [29, 30]. In [31], an

ADRC controller was applied to a power electronic converter to estimate the total power demand and reduce the steady-state error of the output voltage. In [32], a robust voltage control method for a floating interleaving boost converter with a high voltage gain, was proposed. The reference current was obtained by the ADRC controller in the outer loop, whereas the inner loop adopted the super-twisting sliding-mode control (ST-SMC), which greatly improved the voltage tracking and antiinterference ability of the boost converter. Motivated by the advantages of ADRC control, it is a good idea to replace the PI controller in PI-VIC with ADRC controller to stabilize the DCbus voltage under large and unknown disturbances.

Considering the stability problem of the PABTS DC-MG due to the low inertia of power electronic devices and the severe challenges caused by frequent charge and discharge test interferences, a method combining the merits of VIC and ADRC, named ADRC-VIC, is proposed for BGCC converter to enhance the system inertia and improve the anti-interference ability. In the proposed ADRC-VIC control, VIC is used for inertia support, and ADRC is served as the outer loop controller for disturbance rejection. In ADRC-VIC, the neglected system dynamics, uncertainties, and non-repetitive factors caused by non-repetitive disturbances, are defined as a part of the total disturbance to be estimated and compensated. These disturbances are eliminated by feedback compensation, thereby, the anti-interference ability is improved. In summary, the main contributions of this paper are as follows:

- The ADRC controller in the inner loop of ADRC-VIC control is designed according to the virtual inertia equation. The external disturbances (e.g., changes in the grid voltage and load changes) and internal parameter perturbations are regarded as the total estimated disturbance, which are suppressed by feedback compensation of the inner loop ADRC controller. This significantly improves the antiinterference ability of the system.
- 2) The ADRC-VIC on the outer loop is proposed, and the inertia enhancement and robustness improvement of the PABTS DC-MG are realized. This provides a new solution for dc-bus voltage stabilization under frequent charge and discharge tests of the battery test systems.

The remainder of this paper is organized as follows. Section II describes the PABTS DC-MG and its existing problems. To achieve strong robustness against uncertainties and unknown disturbances, an ADRC-VIC scheme is proposed. Section III introduces the concept of VIC and the virtual capacitor configuration for inertia support of a DC-MG. Section IV describes the design of the ADRC controller for internal and external disturbances that may exist in PABTS DC-MG, which greatly enhance the system robustness. In Section V, stability of the system is analyzed. In Section VI, the effectiveness of the proposed method is compared with other techniques by experimental results. Finally, Section VII concludes this article with a future scope of work.

II. SYSTEM DESCRIPTION

A. Problem Description



Fig.2. Control block diagram of the BGCC for PABTS DC-MG.

In this paper, we primarily study the control strategy of the bidirectional converter in the PABTS DC-MG used to suppress the DC-bus voltage fluctuations under different interferences. The power module in Fig.2 is a simplified model of the PABTS DC-MG. U_1 to U_n represent different battery test units, and L_1 to L_n represent the boost inductors. The battery pack is charged and discharged through a bidirectional DC/DC converter, and each DC/DC converter is connected to a DC-bus. Then, it is connected to the grid through a bidirectional grid-connected converter (BGCC). C_{dc} represents the DC bus capacitance, u_{dc} is its terminal voltage, i_0 is the DC-link output current, i_{dc} is the DC-link input current, r is the parasitic resistance of the inductor L, i_{abc} is the grid current, and v_{abc} is the grid voltage. u_d and u_q are the voltage components of v_{abc} under dq-frame, respectively. i_d and i_q are the current components of i_{abc} under dq-frame, respectively, after the Clark and Park transformation. i_d^* and i_q^* are the current references of i_d and i_q , respectively. If the BGCC operates with a unit power factor, namely, $i_q = 0$, $u_q = 0.$

To stabilize the DC-bus voltage, inertia support as well as strong robustness are required. Fig.2 shows three different control schemes for the PABTS DC-MG. These are voltage and current double PI loop controls, namely, inertia-free control (NO-VIC). The MPC-VIC of inertia is increased by compensating for the reference current in the virtual inertia control through the MPC and the ADRC-VIC proposed in this paper. To analyze the suppression effect of the first two schemes on the DC-bus voltage fluctuation in the PABTS DC-MG, the experimental results in [23] were analyzed.

Fig.3 shows the DC-bus voltage fluctuation transient diagrams with different control strategies under charging conditions, in which A-VIC represents adaptive virtual inertia control. When t = 0.16 s, a charging test is performed. The voltage drop is caused by the decrease in power at the DC-bus, and the voltage drop reaches 14 V without inertia support. Evidently, this fluctuation result is large, and NO-VIC strategy is not suitable for the PABTS DC-MG. The A-VIC can automatically release the inertia in the virtual capacitor to maintain the voltage drop is reduced to 10 V.



Fig.3. Response of the DC-bus voltage with different strategies.

In addition to A-VIC, the MPC-VIC calculates the optimal compensation in real time along with the change in the external environment, and superposes the system inertia to the virtual reference current to reduce the voltage fluctuation to 8 V. Although the MPC-VIC method can predict and compensate for the DC-bus current to suppress the DC-bus voltage fluctuation, frequent charge and discharge will still have some impact on the PABTS. Therefore, minimizing the system interference is challenging. This will be elaborated in the subsequent sections.

B. Proposed Control Scheme

The traditional VIC method includes a virtual inertia link and a current inner loop control. Both the outer-loop controller and inner-loop controller adopt the PI controller, but the PI controller has inherent limitations. For example, it is difficult to select appropriate parameters, and the inherent contradiction between rapid response and overshoot is difficult to overcome. In this paper, a controller that can reduce external interference and avoid excessive fluctuation of the DC-bus voltage is designed to suppress the disturbance in the DC-bus voltage. It also improves the robustness of the PABTS DC-MG.

Fig.4 shows a simplified schematic diagram of the PABTS DC-MG with the ADRC-VIC strategy, including the power supply and control strategy parts. The outer loop of the control strategy adopts VIC to enhance the inertia of the system, and the inner loop is the current control. Because the current reference of the inner loop comes from the outer loop, the external interference is primarily introduced into the control system through the sampled voltage and current. However, the traditional PI-VIC method, which adopts proportional-integral (PI) controller for outer-loop voltage control and VIC controller in the inner-loop for inertia support, cannot eliminate the interferences [21, 22]. Different with the traditional PI-VIC, Fig.4 shows the derivation of the external loop controller (ADRC) based on VIC method, which replaces the traditional PI controller to eliminate the interference and suppress the DCbus voltage fluctuation.



Fig.4. Block diagram of the proposed ADRC-VIC method.



For the proposed ADRC-VIC control scheme in Fig.4, a detailed design and explanation of the VIC controller in the outer-loop and ADRC controller in the inner-loop will be given in Section III and IV, respectively.

III. VIC CONTROL OF BGCC

In the DC microgrid shown in Fig. 1, there is no rotating rotor or special energy storage system to provide additional transient compensation power. The AC grid can improve the inertia support for the DC grid, which is realized by implementing a VIC strategy on the bidirectional converter. Under different control strategies, the relationship between the output power of the inverter and the power injected into the DC-bus can be expressed as:

$$P_{out} - P_{in} = \Delta P \tag{1}$$

where ΔP is the power fluctuation at the DC-bus. When the microgrid is stable, $P_{out} = P_{in}$, that is, $\Delta P = 0$. When the PABTS performs charge and discharge tests and load switching occurs in the DC-MG, changes in Pout and Pin lead to an increase in the power fluctuation ΔP . This unbalanced power fluctuation leads to an increase or decrease in the DC-bus voltage. Excessive power fluctuations greatly threaten the stable operation of the DC-MG. The DC bus capacitor C_{dc} will release or absorb power according to the DC-bus voltage fluctuation; however, the suppression effect is limited by the actual capacity. If the additional power is absorbed by a virtual capacitor C_{vir} (see Fig. 5), (1) can be changed to:

$$P_{out} - P_{in} = \Delta P = C_{vir} u_{vir}^* \frac{du_{vir}}{dt}$$
(2)

where u_{vir}^* is the virtual reference for the DC-bus voltage. Equation (2) shows that the DC-bus power change ΔP , which is interfered with by external power, is finally absorbed or released by the DC-link virtual capacitance, thereby stabilizing the DC-bus voltage.

Additionally, as shown in Fig. 5, the virtual capacitor current Δi_0 can be derived by the virtual DC-link current reference i_{dc}^{ref} and the output current i_0 is calculated by:

$$\Delta i_{0} = C_{vir} \frac{du_{vir}^{*}}{dt} = i_{dc}^{ref} - i_{0}$$
(3)

To achieve power sharing, droop control is usually introduced in the virtual reference current i_{dc}^{ref} as the primary voltage regulator, where $i_{dc}^{ref} = k_d(u_0 - u_{dc})$, and damping is introduced in the output current i_0 to prevent power oscillation, where $i_0 = D_b(u_{vir}^* - u_0)$.

Thus, by analogizing the virtual inertia equation of the BGCC with the virtual synchronous machine (as shown in Fig.6) in AC-MG, the virtual inertial control equation can be written as:

$$C_{vir} \frac{du_{vir}^*}{dt} = k_d (u_0 - u_{dc}) - i_0 - D_b (u_{vir}^* - u_0)$$
(4)

where k_d represents droop coefficient, u_0 is rated DC voltage, D_b is damping coefficient. Under the traditional droop control, the output current i_0 is solely influenced by the equivalent resistance $1/k_d$ of the droop loop. The output current in virtual inertia control is jointly determined by $1/k_d$, C_{vir} and D_b .

IV. DESIGN OF ADRC CONTROLLER FOR BGCC

The design of ADRC controller in Fig.4 contains the expanded-state-observer (ESO) and the linear-state-error-feedback (LSEF), which are explained as follows.

A. Block Diagram of the ADRC Controller

Fig. 7 shows the typical structure of an ADRC controller. In traditional current controllers, for any dq-axis signal, the extraction of the differential signal and tracking of the reference signal can be realized. However, for the first-order ADRC controller, there is only one input signal. Thus, the differential of the input signal is not required. In addition, the input signal of ADRC controller in this paper is the dc-link voltage variation $\Delta u (\Delta u = u_{vir} - u_{dc})$ of virtual reference voltage and sampling voltage, and the expected Δu is 0. In view of this special situation, the tracking differentiator (TD) in the first-order ADRC can be omitted. The state variable x and disturbance fare estimated by the ESO through the output u(t) of ADRC controller and sampled grid current i_d . Then, the state error feedback compensation control is carried out with LSEF. Finally, the reference current i_d^* for the inner-loop current controller is obtained. The results show improvement in the anti-interference capability of the system and enhancement of the system robustness.



Fig.7. Block diagram of ADRC controller.

B. Expanded State Observer (ESO)

As the core component of linear active disturbance rejection control technology, a linear extended state observer (LESO) can not only estimate the state variables of the system in real time, but also accurately observe the total disturbance of the system. Therefore, the proposed extended state observer reduces the system model requirements, especially for difficulties in establishing an accurate mathematical model of the controlled system, further amplifying its advantages.

For the bidirectional converter, when ignoring the energy loss of the bridge arm and the loss of the parasitic resistance of the inductance and capacitance, the power balance on both sides of the BGCC can be obtained by:

$$\frac{3}{2}(u_d i_d + u_q i_q) = u_{dc} i_{dc} = u_{dc} (C_{dc} \frac{du_{dc}}{dt} + i_0)$$
(5)

For a three-phase symmetrical AC power supply, $u_q = 0$. To realize the unity power factor control of the three-phase voltage converter, it is necessary to set $i_{qref} = 0$. Thus, (5) can be written as:

$$1.5u_{d}i_{d} = u_{dc}i_{0} + u_{dc}C_{dc}\frac{du_{dc}}{dt}$$
(6)

Combining (6) and (4) yields:

$$\frac{du_{vir}}{dt} = \frac{1}{C_{vir}} \left(\left(k_d + D_b \right) u_0 - k_d u_{dc} + C_{dc} \frac{du_{dc}}{dt} - D_b u_{vir}^* - 1.5 \frac{u_d i_d}{u_{dc}} \right)$$
(7)

Taking $x = u_{vir}^*$, the dynamic voltage state equation can be obtained from (7) as:

$$\begin{cases} \dot{x}(t) = f(x, u_{dc}(t)) + bu(t) \\ y(t) = x(t) \end{cases}$$
(8)

where

$$f(x, u_{dc}(t)) = \frac{k_d}{c_{vir}} (u_0 - u_{dc}) + \frac{c_{dc}}{c_{vir}} \frac{du_{dc}}{d_t} - \frac{D_b}{c_{vir}} u_{vir}^* + \frac{D_b}{c_{vir}} u_0,$$

$$u(t) = i_d, \text{ and } b = -\frac{3u_d}{2c_{vir}u_{dc}}.$$

The input of the system is set to u(t), that is, the given value i_d^* of the current inner loop. The coefficient b is determined by the output voltage u_d of the DC-AC converter and the DC-bus voltage u_{dc} . In $f(x, u_{dc}(t))$, u_0 is the rated DC-bus voltage and is a constant, and there is no interference with the system. The sampling DC-bus voltage u_{dc} changes with the interference of power fluctuation at the DC-bus in DC-MG, which can be generalized as a phenomenon reflecting the strength of external interference. The state variable u_{vir}^* is the final output result of the VIC link, which changes with the variations in the DC-bus voltage and current, and directly affects the input of the ADRC controller, thereby affecting the reference current i_d^* in the current loop. Therefore, $f(x, u_{dc}(t))$ not only contains the disturbance of the external system, but also the perturbation of the parameters of its own control system that affect the output results of the system. Therefore, $f(x, u_{dc}(t))$ is regarded as the sum of all system disturbances. The voltage response of (8) can be simplified using a first-order link.

The design of the first-order ADRC-VIC is based primarily on the nonlinear system of (8). To facilitate the understanding of the derivation process, we first assume that an accurate estimation of the total disturbance $f(x, u_{dc}(t))$ of the system can be achieved, and the estimated value is z_2 , which is given by:

$$z_2 = f(x, u_{dc}(t)) \tag{9}$$

An ESO is the core of the ADRC controller, and its advantage is its low model dependence. In addition to providing the observation values of each order state variable of the system, the ESO can also estimate and compensate for the total disturbance of the system in real time. It has the characteristics of an integral link, which can improve the steady-state accuracy of the system and avoid the stability problem caused by the integral link.

To estimate the total disturbance of the system, it is necessary to expand the state variables. The total disturbance $f(x, u_{dc}(t))$ in (8) is replaced by the expanded state quantity x_2 , and we obtain:

$$\begin{cases} \dot{x}_{1}(t) = x_{2}(t) + bu(t) \\ \dot{x}_{2}(t) = G(t) \\ y(t) = x_{1}(t) \end{cases}$$
(10)

where $x_1 = u_{vir}^*$, $x_2 = f(x, u_{dc}(t))$ are expansion variables, and G(t) is an unknown function. Real-time observation of state variables can be achieved through the ESO. Rewrite (10) into a state-space form:

$$\begin{cases} \dot{x}(t) = Ax(t) + Bu(t) + EG(t) \\ y(t) = Cx(t) \end{cases}$$
(11)

where

$$A = \begin{bmatrix} 0 & 1 \\ 0 & 0 \end{bmatrix}, B = \begin{bmatrix} b \\ 0 \end{bmatrix}, E = \begin{bmatrix} 0 \\ 1 \end{bmatrix}, C = \begin{bmatrix} 1 & 0 \end{bmatrix}$$

The specific algorithm given is:

$$\begin{cases} e_1 = z_1 - y \\ \dot{z}_1 = z_2 - \beta_1 fal_1 + bu(t) \\ \dot{z}_2 = -\beta_2 fal_1 \end{cases}$$
(12)

where z_1 and z_2 are the observation results of x_1 and $f(x, u_{dc}(t))$, respectively. e_1 represents the tracking error, and β_1 and β_2 are the controller parameters.

The nonlinear functions are $fal_x = fal(e_x, \alpha_x, \delta)$ and x = 1, 2. The expression for $fal(e, \alpha, \delta)$ is as follows:

$$fal(e,\alpha,\delta) = \begin{cases} \frac{e}{\delta^{1-\alpha}}, & |e| \le \delta \\ |e|^{\alpha} sign(e), & |e| > \delta > 0 \end{cases}$$
(13)

where δ and α are constants; sign(e) is the sign function.

When $\alpha = 1$, $fal(e, \alpha, \delta) = e_1$. Considering that it is easier to implement control strategies and adjust parameters in industry, e_1 can be used instead of fal_1 in practical engineering to meet the control effect, thus simplifying (12) to

$$\begin{cases} e_1 = z_1 - y \\ \dot{z}_1 = z_2 - \beta_1 e_1 + bu(t) \\ \dot{z}_2 = -\beta_2 e_1 \end{cases}$$
(14)

Equation (14) is the realization of the linear extended observer of the system, and it is rewritten as the state space expression to obtain

$$\begin{cases} \dot{z}(t) = Az(t) + Bu(t) + L(y(t) - \hat{y}(t)) \\ \hat{y}(t) = Cz(t) \end{cases}$$
(15)

where $\mathbf{L} = \begin{bmatrix} \beta_1 & \beta_2 \end{bmatrix}^T$ is the observer gain vector.

When the communication time-delay exists in the control system, the output of the system can be considered as a signal that has lagged, as shown in Fig. 8. To solve this problem, the control signal can also be delayed when it reaches the extended state observer [33], so that the control signal and the system input signal can be resynchronized into the extended state observer, this can accurately estimate the delayed system state and disturbance.





Therefore, the state equation of ESO considering time-delay T_d should be

$$\begin{cases} \dot{z}(t) = Az(t) + Bu(t - T_d) + L(y(t) - \hat{y}(t)) \\ \hat{y}(t) = Cz(t) \end{cases}$$
(16)

Where T_d denotes the one period delay. Compared with conventional ADRC controller, the ESO considering time-delay can effectively improve the bandwidth of the system observer, and can calculate the total disturbance of the system in a wider frequency range [34], thus improving the accuracy of error estimation and the anti-interference capability.

C. Linear State Error Feedback (LSEF)

Introducing the disturbance estimator z_2 as the compensation to the control system.

$$u(t) = (u_0(t) - z_2) / b \tag{17}$$

Formula (17) is introduced into (8). Since z_2 is the total disturbance estimator $f(x, u_{dc}(t))$ of the system, when the total disturbance estimation value is close to its real value, $z_2 \approx f(x, u_{dc}(t))$, then $\dot{y} \approx u_0(t)$ can be used to eliminate the error.

$$\dot{y} = f(x, u_{dc}(t)) + u_0(t) - z_2 \approx u_0(t)$$
 (18)

The nonlinear state error feedback (NLSEF) rate refers to the nonlinear relationship between the input of the feedback system and the error of the state variable. The control objective of ADRC is to force the voltage fluctuation change $\Delta u = 0$, and the control law can be expressed as

$$\begin{cases} e_2 = \Delta u - z_1 \\ u_0(t) = \beta_3 fal_2 \\ u(t) = (u_0(t) - z_2) / b \end{cases}$$
(19)

where e_2 is the difference between the Δu and z_1 , and β_3 is the controller parameter.

Similar to the design in ESO. Considering the realization of control algorithm in industry and the easy adjustment of parameters, we take $\alpha = 1$, namely $fal_2 = e_2$, so (19) can be expressed as the linear error feedback control.

This article has been accepted for publication in IEEE Transactions on Smart Grid. This is the author's version which has not been fully edited and content may change prior to final publication. Citation information: DOI 10.1109/TSG.2022.3184985

IEEE TRANSACTIONS ON SMART GRID

$$\begin{cases} e_2 = \Delta u - z_1 \\ u_0(t) = \beta_3 e_2 \\ u(t) = (u_0(t) - z_2) / b \end{cases}$$
(20)

D. Parameter Tuning of ADRC Controller

The rationality of parameter setting of ESO and LSEF in ADRC controller directly affects the control effect. The parameters of each link are set separately through the separation principle. Parameters to be tuned include gain matrix $\boldsymbol{L} = [\beta_1 \quad \beta_2]^T$ in ESO, and β_3 in LSEF control.

The parameter tuning of the observer by pole assignment is one of the common methods [35]. The pole assignment of ESO expression (15) is carried out and its characteristic equation is obtained according to (A - LC)

$$D(s) = s^{2} + \beta_{1}s + \beta_{2}$$
(21)

The stability condition of the observer is that the characteristic roots of (21) are located in the left-half-plane (LHP) of the *s*-domain. According to Routh criterion, stability is satisfied as long as $\beta_1 > 0$ and $\beta_2 > 0$ are true for (21). When the characteristic root is farther away from the virtual axis, the stability margin of the system is larger. In order to keep β_1 and β_2 away from the imaginary axis as far as possible, the root of the characteristic equation (21) should be equal, that is, $\beta_1^2 = 4\beta_2$. In addition, the characteristic root (pole) should be set at $-\omega_0$, and ω_0 is the bandwidth of the observer. Thereby, $\beta_1 = 2\omega_0$, $\beta_2 = \omega_0^2$.

Similarly, β_3 can be configured by the closed-loop transfer function poles of the feedback control system. In (20), the output of LSEF can be expressed as

$$u_0(t) = \beta_3(\Delta u(t) - z_1(t))$$
(22)

$$\dot{y} + \beta_3 y = \beta_3 \Delta u \tag{23}$$

From (23), the transfer function of the closed-loop control system after disturbance compensation can be derived as

$$G_{yu}(s) = \frac{y(s)}{\Delta u(s)} = \frac{\beta_3}{s + \beta_3}$$
(24)

The pole $-\beta_3$ of (24) should be set at $-\omega_c$, and ω_c is the control bandwidth. Therefore, $\beta_3 = \omega_c$. ω_c can be determined by choosing the controller bandwidth based on common experience [35], thus, $\omega_0 = (1/5 \sim 1/2)\omega_c$.

Through the above analysis, the appropriate initial bandwidth is preliminarily selected, and then further optimized in the experiment. The parameter tune results are shown in Table II.

V. STABILITY ANALYSIS

ADRC controller as the most popular of disturbance suppression strategy, its capability to estimate the disturbances and state variables as well as its stability will directly affect the DC-bus voltage fluctuation suppression effect of the whole control system. Therefore, it is necessary to analyze the system stability with ADRC controller.

To facilitate the study of the system stability in *s*-domain, by simplifying (16), z_1 and z_2 can be derived as

$$z_1 = \frac{\beta_1 y + \beta_3 \Delta u}{s + \beta_1 + \beta_2} \tag{25}$$

$$z_2 = \frac{\beta_2 y_s + \beta_2 \beta_3 (y - \Delta u)}{s(s + \beta_1 + \beta_3)}$$
(26)

Combining (17), (22), (25) and (26), the ADRC control law can be expressed as $f(x) = C_1(x) + C_2(x) + C_2(x)$

$$u(s) = G_a(s) \cdot \Delta u(s) - G_b(s) \cdot y(s)$$
(27)
Where G_a and G_b are expressed as

$$G_{a}(s) = \frac{\beta_{3}(s^{2} + \beta_{1}s + \beta_{2})}{bs(s + \beta_{1} + \beta_{3})}$$
(28)

$$G_b(s) = \frac{(\beta_1 \beta_3 + \beta_2)s + \beta_2 \beta_3}{bs(s + \beta_1 + \beta_3)}$$
(29)

After converting the dynamic voltage state equation (8) of the controller in *s*-domain, and substitute (27) into (8), the output of ADRC controller is obtained as

$$y(s) = \frac{1}{s} (f(s) + bu(s))$$

$$= \frac{1}{s} (f(s) + b(G_a(s) \cdot \Delta u(s) - G_b(s) \cdot y(s)))$$
(30)

where f(s) is the total disturbances in *s*-domain, simplify (30) to obtain

$$y(s) = \frac{(s + \beta_1 + \beta_3) \cdot s}{(s + \beta_3)(s^2 + \beta_1 s + \beta_2)} f(s) + \frac{\beta_3}{s + \beta_3} \Delta u(s)$$

= $G_{vt}(s) f(s) + G_{vu}(s) \Delta u(s)$ (31)

In (31), the output of ADRC controller is affected by the total disturbance f(s) and the voltage error $\Delta u(s)$. Combined with the analysis in Section IV-D and (31), it is obvious that the system stability is closely related to the observer and control bandwidth, and the system stability can be improved by selecting the appropriate bandwidth.

When the influence of disturbance on the output is ignored, system (31) is simplified to (24), and its output only contains Δu . At this time, the control performance is only determined by ω_c , which is independent of ω_0 . The Bode diagram of $G_{yu}(s)$ is plotted in Fig. 9, indicating that the increase of broadband ω_c not only reduces the phase-delay, but almost does not affect the high frequency characteristics, and the stability margin and tracking speed of the system are improved.



Fig. 9. Block diagram of $G_{yu}(s)$ by changing the control bandwidth ω_c .

When ignoring Δu and only considering the influence of total disturbance f(s) on the system, the transfer function from y to f is $G_{vf}(s)$, and its Bode diagram is shown in Figs. 10 and 11. The system stability is jointly determined by the control bandwidth and the ESO bandwidth. Increasing ω_0 or ω_c can reduce the disturbance gain to enhance the anti-disturbance capability of the controller.



Fig. 10. Block diagram of $G_{vf}(s)$ by changing the observer bandwidth ω_0 .



Fig. 11. Block diagram of $G_{yf}(s)$ by changing the control bandwidth ω_c .

VI. EXPERIMENTAL RESULTS

Hardware Setup Α.

To successfully demonstrate the effectiveness of the proposed ADRC-VIC for DC-link voltage stabilization, experimental verifications are carried out. The experiments are conducted in a laboratory PABTS DC-MG prototype shown in Fig.12. The DC-MG is constituted by a BGCC converter, two DC-DC converters for charging and discharging test control, two Lithium-Ion power battery packs for Tesla Motors (Model-S 85), and a programmable Chroma 63208 DC electronic load which is designed to test the DC power supplies, power electronic devices, automotive batteries, and components.

The experimental BGCC is composed by a 20-kW SiC-based two-level grid-connected converters. The control scheme in Fig.8 is implemented with a 32-bit float-point digital signal processor (DSP) TMS320F28377D from Texas Instruments, which is usually used for fast, complicated mathematics calculations and control algorithm implementation. All the SiC



Fig. 12. Configuration of the PABTS DC-MG in experiment.

TABLE I PARAMETER SPECIFICATIONS OF THE POWER BATTERY IN TESLA MODEL3S

Parameters	Value	
Nominal voltage	355.2 V	
Rated capacity (Ah)	147.5 Ah	
Initial state-of-charge	50%	

TABLE II	
	ADDC M

PARAMETER SPECIFICATIONS OF THE ADRC-VIC CONTROLLER							
	Parameters	Values	Parameters	Values	lues		
	U_{dc}	700 V	k _d	38			
	V_g	220 V	D_b	30			
	f_o	50 Hz	k_p	20			
	L	10 mH	k_i	22			
	C_{dc}	1350 μF	ω_0	40 rad/s			
	C_{vir}	0.5 m <i>F</i>	ω_c	175 rad/s			
_	L	10 mH	k _i	22			

power MOSFETs (LSIC1M120E0080 with 1200V/25A and $R_{ds(on)} = 80 \text{ m}\Omega$) from Littelfuse power semiconductors are driven by the isolation driver ISO5852S. The switching frequency is 10 kHz. Three hall current sensors (HCS-LTS-06A) are used for grid-side current measurements.

The verification of PI-VIC (the outer loop adopts virtual inertia control, and the inner loop controller adopts a PI controller, which is the current control) [21], MPC-VIC [23], and ADRC-VIC are performed. To simplify the battery testing, all battery discharge and charge modes are set to have a constant current during the experiment. The parameters of the power battery for charging and discharging test, ADRC-VIC, and PI controller are listed in Tables I and II. The battery parameters are referenced to the widely used batteries (Lithium iron phosphate battery) in electric vehicle TESLA MODEL3S. Fig.12 gives the configuration of a PABTS DC-MG in

experiment, in which two batteries are parallel connected, thus the parallel DC-DC converters and the BGCC form a DC-MG. The initial state of the DC-MG is defined as that there is battery-I for a 25A discharge test, and the system enters steady state. Based on this, the experiments contained the following scenarios, each comparing two cases. (1) Charging and discharging current tests of the batteries (Cases I and II). (2) The DC-bus voltage under grid voltage and load changes (Cases III and IV).



Fig. 13. Configuration of the PABTS DC-MG in experiment.

B. Result and Analysis

Case I: Charging Current Test

Assuming the PABTS DC-MG is in initial state, Battery-II was added to the system during the battery charging test, as shown in Fig.14 (a). The rechargeable battery-II is added to the system for charging at 0.16 s. The state-of-charge (SOC) gradually increases from the initial 50%, charging current stabilizes at 5 A, and terminal voltage of the battery is as large as 355.5 V. Fig.14 (b) shows the DC-bus voltage fluctuations under different control strategies. After the charging test was performed at 0.16 s, the power at the DC-bus was reduced and the DC-bus voltage dropped. Under the PI-VIC, despite providing inertia support, the maximal voltage-drop reached about 9 V. In the MPC-VIC proposed in [23], the MPC compensates for a suitable virtual reference current at the instance of charging transient to improve the inertial support capability of the VIC, and the voltage fluctuation is reduced to 5.6 V. MPC-VIC increases inertia to reduce DC-bus voltage fluctuations by changing the virtual current. Although the virtual reference current compensation can be appropriately increased to improve the suppression voltage fluctuations, this method still has an upper limit. The given reference current of the inner loop in VIC comes from the outer loop, and the outer loop input comes from the real-time sampled DC-bus voltage and current. The interference in the system can only come from the collected voltage and current; thus, the proposed ADRC-VIC uses the estimation of the system and outer loop error. It then uses feedback compensation to eliminate disturbance and suppresses the fluctuation of the DC-bus voltage by eliminating the interferences. The DC-bus voltage fluctuation with ADRC-VIC is significantly reduced (approximately 2.3 V), which proves its effectiveness.

Case II: Discharge Current Test

In initial state, to evaluate the discharging behavior of the batteries, battery-II was added for the discharge test at 0.16 s. Fig. 15 (a) shows the waveforms of the SOC, current, and voltage of the batteries during the discharge test. The SOC



Fig. 14. DC-bus voltage under charging test of battery-II. (a) SOC, battery current, and voltage; (b) Dynamic response of the DC-bus voltage with different control methods.

gradually decreases from the initial 50%, charging current is 5 A, and terminal voltage of battery-II is stable at 354 V. Fig. 15 (b) shows a comparison of the DC-bus voltage fluctuations under different control strategies. Owing to the addition of the discharge test, the power at the DC-bus and the voltage fluctuation increase. Under VIC, the DC-bus voltage fluctuation caused by battery discharge is 7.1 V. Based on this, virtual current compensation (MPC-VIC method) was included in [23] to further improve the voltage fluctuation suppression ability, and the results show that the voltage fluctuation is reduced to 3.5 V. In the proposed ADRC-VIC, the interference from the discharge input power is reflected in the voltage and current input controlled by the VIC. The ADRC controller uses the input disturbance of the external loop voltage and the system disturbance estimation. The feedback compensation is used to eliminate the disturbance and suppress the voltage fluctuation. The results show that the voltage fluctuation is only 1.5 V under the discharge interference. This demonstrates its effectiveness in discharging disturbance.





Fig. 15. DC-bus voltage under discharging test of battery-II. (a) Discharge current test; (b) DC-bus voltage with different control methods.

Case III: DC-bus Voltage under Grid Voltage Changes

The fluctuation of the grid voltage also causes interference in the PABTS DC-MG. Fig. 16 (a) shows the voltage fluctuation of the power grid. The voltage increases by 22% at t = 0.2 s, and the voltage recovers at t = 0.3 s. The results of the DC-bus voltage fluctuations under different control strategies are shown in Fig. 16 (b). It is evident that when the grid voltage fluctuates, the system has relatively obvious DC-bus voltage fluctuations under the control of the traditional VIC and MPC-VIC. In the ADRC, the impact of grid voltage fluctuations is limited to under 0.4 V, thus, demonstrating strong anti-interference suppression capability. The proposed strategy is significantly better than the other methods, that proves its effectiveness.



Fig. 16. DC-bus voltage under the change of grid voltage. (a) Grid-voltage; (b) DC-bus voltage.

Case IV: DC-bus Voltage under Load Changes

The load switching on the DC-bus also affects the voltage fluctuation at the DC-bus. As shown in Fig. 17, when the system is in initial state and battery-II is disconnected from the DC-MG, a resistive load of 4 kW is added at t = 0.2 s, and it is removed at t = 0.3 s. Fig.17(a) shows the experimental results. In initial state, the discharge test was performed for battery-I, and the power is delivered to the DC-bus. After the load is added, the DC-bus power decreases, resulting in a voltage drop and decrease in the grid current. When the load is removed, the DC-bus power is restored, voltage increases and current is restored. Fig. 17 (b) shows the voltage fluctuations under different control strategies. In the traditional VIC and MPC-VIC, the

voltage fluctuations caused by load addition and removal are almost equal, but the MPC-VIC fluctuations are small. In the proposed ADRC-VIC, the interference caused by load fluctuations can be eliminated. The DC-bus voltage fluctuation is 1.3 V, which greatly suppresses the interference. The experiment verifies the effectiveness of the proposed scheme.



Fig. 17. Grid current and DC-bus voltage under load changes. (a) Three-phase grid current. (b) DC-bus voltage with different control methods.

C. Enhancement on DC-bus Voltage Stability

To clearly demonstrate the effectiveness of the proposed method, the aforementioned experimental results are analyzed and compared in Tables III and IV.

TABLE III							
DC-BUS VOLTAGE FLUCTUATION PERCENTAGE WITH DIFFERENT METHODS							
Methods	Case I	Case II	Case III	Case IV			
DI VIC [21 22]	9 V	7.1 V	1.8 V	6.5 V			
FI-VIC [21,22]	(1.29%)	(1.00%)	(0.26%)	(0.93%)			
MDC MIC [22]	5.6 V	3.5 V	1.2V	4.4 V			
MPC-VIC [25]	(0.8%)	(0.5%)	(0.17%)	(0.63%)			
	2.3 V	1.5 V	0.4 V	1.3 V			
ADRC-VIC	(0.33%)	(0.24%)	(0.06%)	(0.19%)			
IABLE IV							
DC-BUS VOLTAGE STABILITY ENHANCEMENT OF ADRC OVER OTHER							
	0	NTROL METHO	DS				
Methods	Case I	Case II	Case III	Case IV			
ת	3.3 V	2V	0.8 V	3.1 V			
D _{MPC-VIC}	(58.9%)	(57.1%)	(66.6%)	(70.4%)			
מ	6.7 V	5.6V	1.4 V	5.2 V			
D_{PI-VIC}	(74.4%)	(78.8%)	(77.8%)	(80%)			

Table III shows the DC-bus voltage fluctuations with different control strategies and their proportions to the reference (700 V here). Their proportions to the dc-link reference is calculated by (32), where $V_{peak}(t_p)$ and $V(t_{\infty})$ represent the peak and steady-state DC-bus voltage. *D* is the dc-bus voltage fluctuation percentage. Table IV shows the DC-bus voltage fluctuation reduction and the percentage of ADRC relative to PI-VIC and MPC-VIC methods. The increased percentage is calculated by $D_{MPC-VIC}$ in (33) and D_{PI-VIC} in (34), where V_{PI-VIC}^{DC} , $V_{MPC-VIC}^{DC}$ and $V_{ADRC-VI}^{DC}$ represent the DC-bus voltage with PI-VIC, MPC-VIC and ADRC-VIC control methods. As

shown in Table III, under different disturbances, the DC-bus voltage fluctuation with ADRC-VIC will not exceed 0.5% of its reference. Table IV shows that, the DC-bus voltage fluctuation suppression effect with the proposed ADRC is increased by 58.9 %, 57.1 %, 66.6 % and 70.4 % when compared with MPC-VIC in four scenarios. Moreover, compared with traditional PI-VIC, the improvements are about 74.4 %, 78.8 %, 77.8 % and 80 %, respectively. Therefore, when external interference occurs, traditional VIC is not sufficient for stabilizing the DCbus voltage. Although the virtual reference current compensation is provided in MPC-VIC, voltage fluctuation suppression cannot be minimized. Compared with MPC-VIC and PI-VIC, the proposed ADRC-VIC is obviously more robust in anti-interference, and is recommended for PABTS DC-MG where frequently charging and discharging test of the electric vehicle batteries are required.

$$D = \frac{\left| V_{peak}(t_p) - V(t_{\infty}) \right|}{V(t_{\infty})} \%$$
(32)

$$D_{MPC-VIC} = \frac{\left| V_{MPC-VIC}^{DC} - V_{ADRC-VIC}^{DC} \right|}{\left| V_{MPC-VIC}^{DC} \right|} \%$$
(33)

$$D_{PI-VIC} = \frac{\left| V_{PI-VIC}^{DC} - V_{ADRC-VIC}^{DC} \right|}{\left| V_{PI-VIC}^{DC} \right|} \%$$
(34)

VII. CONCLUSION

This paper presents an ADRC-VIC method to enhance the robustness of the PABTS DC-MG. The ADRC-VIC adopts the VIC to enhance system inertia, and the outer loop controller adopted the ADRC. It is modeled by the VIC equation, considering the fluctuations of the DC-bus voltage and current, and the influence of the grid current. The known charge and discharge interference, load switching, neglected system dynamics, and uncertainty interference are defined as the estimated total disturbances. Feedback compensation control is carried out, which reduces the sensitivity of the external and system parameters and stabilized the DC-link voltage of the DC-MG. Compared with traditional PI-VIC and MPC-VIC methods, the proposed ADRC-VIC control significantly suppresses the interference of external disturbances with the system. Finally, its effectiveness is verified under different scenarios.

References

- B. Frieske, M. Kloetzke, and F. Mauser, "Trends in vehicle concept and key technology development for hybrid and battery electric vehicles," 2013 World Electric Vehicle Symposium and Exhibition (EVS27), pp. 1-12, 2013.
- [2] Y. Gui, R. Han, J. M. Guerrero, J. C. Vasquez, B. Wei, and W. Kim, "Large-Signal Stability Improvement of DC-DC Converters in DC Microgrid," in *IEEE Transactions on Energy Conversion*, vol. 36, no. 3, pp. 2534-2544, 2021.
- [3] P. Prabhakaran and V. Agarwal, "Novel Boost-SEPIC Type Interleaved DC–DC Converter for Mitigation of Voltage Imbalance in a Low-Voltage Bipolar DC Microgrid," *in IEEE Transactions on Industrial Electronics*, vol. 67, no. 8, pp. 6494-6504, 2020.
- [4] B. Long, Y. Liao, K. T. Chong, J. Rodríguez, and J. M. Guerrero, "MPC-Controlled Virtual Synchronous Generator to Enhance Frequency and

Voltage Dynamic Performance in Islanded Microgrids, " in IEEE Transactions on Smart Grid, vol. 12, no. 2, pp. 953-964, 2021.

- [5] M. Alshareef, Z. Lin, F. Li, and F. Wang, "A grid interface current control strategy for DC microgrids," in CES Transactions on Electrical Machines and Systems, vol. 5, no. 3, pp. 249-256, 2021.
- [6] U. Manandhar, B. Wang, X. Zhang, G. H. Beng, Y. Liu, and A. Ukil, "Joint Control of Three-Level DC–DC Converter Interfaced Hybrid Energy Storage System in DC Microgrids," *IEEE Transactions on Energy Conversion*, vol. 34, no. 4, pp. 2248-2257, 2019.
- [7] L. He, Y. Li, J. M. Guerrero, and Y. Cao, "A Comprehensive Inertial Control Strategy for Hybrid AC/DC Microgrid With Distributed Generations," in *IEEE Transactions on Smart Grid*, vol. 11, no. 2, pp. 1737-1747, 2020.
- [8] Y. Guo, W. Ma, J. Meng, and Y. Wang, "A Virtual Inertia Control Strategy for Dual Active Bridge DC-DC Converter," 2018 2nd IEEE Conference on Energy Internet and Energy System Integration (E12), pp. 1-5, 2018.
- [9] M. Mokhtar, M. I. Marei, and A. A. El-Sattar, "An Adaptive Droop Control Scheme for DC Microgrids Integrating Sliding Mode Voltage and Current Controlled Boost Converters," in *IEEE Transactions on Smart Grid*, vol. 10, no. 2, pp. 1685-1693, 2019.
- [10] A. C. Braitor, G. C. Konstantopoulos, and V. Kadirkamanathan, "Current-Limiting Droop Control Design and Stability Analysis for Paralleled Boost Converters in DC Microgrids," *in IEEE Transactions on Smart Grid*, vol. 10, no. 2, pp. 1685-1693, 2021.
- [11] X. L. e. al, "Observer-Based DC Voltage Droop and Current Feed-Forward Control of a DC Microgrid," in *IEEE Transactions on Smart Grid*, vol. 9, no. 5, pp. 5207-5216, 2018.
- [12] S. Peyghami, H. Mokhtari, and F. Blaabjerg, "Autonomous Operation of a Hybrid AC/DC Microgrid with Multiple Interlinking Converters," in IEEE Transactions on Smart Grid, vol. 9, no. 6, pp. 1-1, 2018.
- [13] J. Wang, C. Jin, and P. Wang, "A Uniform Control Strategy for the Interlinking Converter in Hierarchical Controlled Hybrid AC/DC Microgrids," in *IEEE Transactions on Industrial Electronics*, vol. 65, no. 8, pp. 6188-6197, 2018.
- [14] D. Dam and H. Lee, "A Power Distributed Control Method for Proportional Load Power Sharing and Bus Voltage Restoration in a DC Microgrid," in IEEE Transactions on Industry Applications, vol. 54, no. 4, pp. 3616-3625, 2018.
- [15] Z. Wang, F. Liu, Y. Chen, S. H. Low, and S. Mei, "Unified Distributed Control of Stand-alone DC Microgrids," *in IEEE Transactions on Smart Grid*, vol. 10, no. 1, pp. 1013-1024, 2019.
 [16] N. Hou and Y. Li, "Communication-Free Power Management Strategy for
- [16] N. Hou and Y. Li, "Communication-Free Power Management Strategy for the Multiple DAB-Based Energy Storage System in Islanded DC Microgrid," *IEEE Transactions on Power Electronics*, vol. 36, no. 4, pp. 4828-4838, 2021.
- [17] L. Xing *et al.*, "Distributed Secondary Control for Current Sharing and Voltage Restoration in DC Microgrid," *IEEE Transactions on Smart Grid*, vol. 11, no. 3, pp. 2487-2497, 2020.
- [18] N. Zhi, K. Ding, L. Du, and H. Zhang, "An SOC-Based Virtual DC Machine Control for Distributed Storage Systems in DC Microgrids," *IEEE Transactions on Energy Conversion*, vol. 35, no. 3, pp. 1411-1420, 2020.
- [19] U. Manandhar, B. Wang, X. Zhang, G. H. Beng, Y. Liu, and A. Ukil, "Joint Control of Three-Level DC–DC Converter Interfaced Hybrid Energy Storage System in DC Microgrids," in *IEEE Transactions on Energy Conversion*, vol. 34, no. 4, pp. 2248-2257, 2019.
- [20] T. R. Oliveira, W. W. A. G. Silva, and P. F. Donoso-Garcia, "Distributed Secondary Level Control for Energy Storage Management in DC Microgrids," *in IEEE Transactions on Smart Grid*, vol. 8, no. 6, pp. 2597-2607, 2017.
- [21] W. W. e. al., "A Virtual Inertia Control Strategy for DC Microgrids Analogized With Virtual Synchronous Machines," *in IEEE Transactions on Industrial Electronics*, vol. 64, no. 7, pp. 6005-6016, 2017.
 [22] X. Zhu, F. Meng, Z. Xie, and Y. Yue, "An Inertia and Damping Control
- [22] X. Zhu, F. Meng, Z. Xie, and Y. Yue, "An Inertia and Damping Control Method of DC–DC Converter in DC Microgrids," *in IEEE Transactions on Energy Conversion*, vol. 35, no. 2, pp. 799-807, 2020.
- [23] B. Long, W. Zeng, J. Rodríguez, J. M. Guerrero, and K. T. Chong, "Voltage Regulation Enhancement of DC-MG Based on Power Accumulator Battery

Test System: MPC-Controlled Virtual Inertia Approach," in IEEE Transactions on Smart Grid, 2021.

- [24] Y. Wang, L. Tao, P. Wang, X. Ma, P. Cheng, and D. Zhao, "Improved Linear ADRC for Hybrid Energy Storage Microgrid Output-side Converter," in IEEE Transactions on Industrial Electronics, 2021.
- [25] W. Chen, J. Yang, L. Guo, and S. Li, "Disturbance-Observer-Based Control and Related Methods—An Overview," in *IEEE Transactions on Industrial Electronics*, vol. 63, no. 2, pp. 1083-1095, 2016.
- [26] S. Baek, Y. Cho, and J.-S. Lai, "Average Periodic Delay-Based Frequency Adaptable Repetitive Control With a Fixed Sampling Rate and Memory of Single-Phase PFC Converters," in *IEEE Transactions on Power Electronics*, vol. 36, no. 6, pp. 6572-6585, 2021.
- [27] M. Parvez, M. F. M. Elias, N. A. Rahim, F. Blaabjerg, D. Abbott, and S. F. Al-Sarawi, "Comparative Study of Discrete PI and PR Controls for Single-Phase UPS Inverter," in *IEEE Access*, vol. 8, pp. 45584-45595, 2020.
- [28] B. Long, P. Lu, K. T. Chong, J. Rodriguez, and J. M. Guerrero, "Robust Fuzzy-Fractional-Order Nonsingular Terminal Sliding-Mode Control of An LCL-Type Grid-Connected Converter," in IEEE Transactions on Industrial Electronics, no. 99, pp. 1-1, 2021.
- [29] K. L. e. al, "Active Disturbance Rejection Control Design With Suppression of Sensor Noise Effects in Application to DC–DC Buck Power Converter," in *IEEE Transactions on Industrial Electronics*, vol. 69, no. 1, pp. 816-824, 2022.
- [30] W. Xue, W. Bai, S. Yang, K. Song, Y. Huang, and H. Xie, "ADRC With Adaptive Extended State Observer and its Application to Air–Fuel Ratio Control in Gasoline Engines," in *IEEE Transactions on Industrial Electronics*, vol. 62, no. 9, pp. 5847-5857, 2015.
- [31] R. Ma, L. Xu, R. Xie, D. Zhao, Y. Huangfu, and F. Gao, "Advanced Robustness Control of DC–DC Converter for Proton Exchange Membrane Fuel Cell Applications," in *IEEE Transactions on Industry Applications*, vol. 55, no. 6, pp. 6389-6400, 2019.
- [32] Y. Huangfu, S. Zhuo, F. Chen, S. Pang, D. Zhao, and F. Gao, "Robust Voltage Control of Floating Interleaved Boost Converter for Fuel Cell Systems," *in IEEE Transactions on Industry Applications*, vol. 54, no. 1, pp. 665-674, 2018.
- [33] Z. S and G. Z., "Modified active disturbance rejection control for time-delay systems," *ISA Transactions*, pp. 53(4): 882-888, 2014.
 [34] A. Benrabah, D. Xu, and Z. Gao, "Active Disturbance Rejection Control of
- [34] A. Benrabah, D. Xu, and Z. Gao, "Active Disturbance Rejection Control of LCL Filtered Grid-Connected Inverter Using Padé Approximation," in IEEE Transactions on Industry Applications, vol. 54, no. 6, p. 6189, 2018.
- [35]Z. Gao, "Scaling and bandwidth-parameterization based controller tuning," in Proc. Amer. Control Conf., vol. 6, pp. 4989–4996, 2003.



Bo Long (S'08–M'10) received the B.S. degree in electrical engineering from the Xi'an Petroleum University, Xian, China, in 2001, and the Ph.D. degree in electrical engineering from Xian Jiaotong University, Shanxi, China, in 2008. He joined the Department of Power Electronics, School of Mechatronics Engineering, UESTC, in 2008, and has been promoted to an Associate Professor since 2014. From 2017 to 2018, he was a Visiting Scholar (Guest Post-Doctoral Researcher) in the area of renewable energy and microgrids with the Department of Electrical Engineering, Tsinghua

University, Beijing, China. His research interests include ac/dc microgrids, grid-connected converters for renewable energy systems and DGs, model predictive control, power quality, multilevel converters, ac motor control, and resonance suppression technique for smart grid applications. He has authored over 20 SCIE-indexed journal papers and one book chapter in the area of power electronics, motor control, battery management system, and smart grid. He has seven issued and 10 pending patents. He is currently the supervisor for eleven master students, two of which have been nominated as provincial outstanding graduate student of UESTC. He is an active Reviewer for the IEEE TRANSACTIONS ON POWER ELECTRONICS, ISA TRANSACTIONS, APPLIED ENERGY, ENERGY, the IEEE TRANSACTIONS ON SMART GRID, the IEEE TRANSACTIONS ON SUSTAINABLE ENERGY, and the IEEE TRANSACTIONS ON SUSTAINABLE ENERGY, and the IEEE TRANSACTIONS ON ENERGY CONVERSION.



Wei Zeng received the B.S. degree in mechanical engineering from Chongqing Technology and Business University, Chongqing, China, in 2019. He is currently pursuing the M.S. degree in mechanical engineering from University of Electronic Science and Technology of China, Chengdu, China. His current research interest is the optimization of direct microgrids, involving virtual inertia control, model predictive control, fractional order systems, ADRC controller design and so on.



José Rodríguez (M'81-SM'94-F'10) received the Engineer degree in electrical engineering from the Universidad Tecnica Federico Santa Maria, in Valparaiso, Chile, in 1977 and the Dr.-Ing. degree in electrical engineering from the University of Erlangen, Erlangen, Germany, in 1985. He has been with the Department of Electronics Engineering, Universidad Tecnica Federico Santa Maria, since 1977, where he was a full professor and President. Since 2015 he is the President of Universidad Andres Bello in Santiago, Chile. He has co-authored

two books, several book chapters, and more than 400 journal and conference papers. His main research interests include multilevel inverters, new converter topologies, control of power converters, and adjustable-speed drives. He has received a number of best paper awards from journals of the IEEE. Dr. Rodriguez is a member of the Chilean Academy of Engineering. In 2014 he received the National Award of Applied Sciences and Technology from the government of Chile. In 2015, he received the Eugene Mittelmann Award from the Industrial Electronics Society of the IEEE.



Cristian Garcia (Member, IEEE) received the M.Sc. and Ph.D. degrees in electronics engineering from the Universidad Tecnica Federico Santa Maria, Valparaiso, Chile, in 2013 and 2017, respectively. From 2017 to 2019, he was with the Engineering Faculty with the Universidad Andres Bello, Santiago, Chile, as an Assistant Professor. Since 2019, he has been with the Department of Electrical Engineering, University of Talca, Curico, Chile, where he is currently an Assistant Professor. During 2016, he was a visiting Ph.D. student with Power Electronics Machines and Control (PEMC) Group.

University of Nottingham, U.K. His research interests include electric transportation applications, variable-speed drives, and model predictive control of power converters and drives.



Josep M. Guerrero (S'01-M'04-SM'08-FM'15)

received the B.S. degree in telecommunications engineering, the M.S. degree in electronics engineering, and the Ph.D. degree in power electronics from the Technical University of Catalonia, Barcelona, in 1997, 2000 and 2003, respectively. Since 2011, he has been a Full Professor with the Department of Energy Technology, Aalborg University, Denmark, where he is responsible for the Microgrid Research Program. From 2014 he is chair Professor in

Shandong University; from 2015 he is a distinguished guest Professor in Hunan University; and from 2016 he is a visiting professor fellow at Aston University, UK, and a guest Professor at the Nanjing University of Posts and Telecommunications. From 2019, he became a Villum Investigator by The Villum Fonden, which supports the Center for Research on Microgrids (CROM) at Aalborg University, being Prof. Guerrero the founder and Director of the same center (www.crom.et.aau.dk). His research interests are oriented to different microgrid aspects, including power electronics, distributed energy-storage systems, hierarchical and cooperative control, energy management systems, smart metering and the internet of things for AC/DC microgrid clusters and islanded microgrids. Specially focused on microgrid technologies applied

to offshore wind, maritime microgrids for electrical ships, vessels, ferries and seaports, and space microgrids applied to nanosatellites and spacecrafts. Prof. Guerrero is an Associate Editor for a number of IEEE TRANSACTIONS. He has published more than 600 journal papers in the fields of microgrids and renewable energy systems, which are cited more than 50,000 times. He received the best paper award of the IEEE Transactions on Energy Conversion for the period 2014-2015, and the best paper prize of IEEE-PES in 2015. As well, he received the best paper award of the Journal of Power Electronics in 2016. During six consecutive years, from 2014 to 2019, he was awarded by Clarivate Analytics (former Thomson Reuters) as Highly Cited Researcher with 50 highly cited papers. In 2015 he was elevated as IEEE Fellow for his contributions on "distributed power systems and microgrids."



Kil To Chong received the Ph.D. degree in mechanical engineering from Texas A&M University, in 1995. He is currently a Professor and the Department Head of the School of Electronics and Information Engineering and a member and the Head of the Advanced Electronics and Information Research Center, Chonbuk National University, Jeonju, South Korea. His research interests include motor fault detection and control, network system control, sensor network systems, time-delay systems, and neural networks